

Continued from Previous Page

Lab Sample#: 2101820-01		Sample Address:		Sample Point: TP-1		Surface:		Sample Date: 05/12/2021		Sample Time: 10:20:00	
Sample Matrix: DW-H20		Description: AFTER TREATMENT & BEFORE DISTRIBUTION EP (INTERVALE WE		Qualifiers	MCL	RL	High Limit	Low Limit	Analysis Date	Analyst	
Test (Method)/Analyte	Result	Unit									
Color (L-10-308-00-1-A)	<5	PCU		15		5			05/13/2021 16:24:57	M.E.	
DW_Anions_IC (300.0)											
Sulfate	8	mg/L		250		1			05/13/2021 01:28:00	T.N.	
Fluoride	<0.1	mg/L		4		0.1			05/13/2021 01:28:00	T.N.	
Chloride	22	mg/L		250		1			05/13/2021 01:28:00	T.N.	
Nitrite Nitrogen	<0.05	mg/L		1		0.05			05/13/2021 01:28:00	T.N.	
Nitrate Nitrogen	0.18	mg/L		10		0.05			05/13/2021 01:28:00	T.N.	
METALS_200.8 (200.8)											
Total Hardness	34	mg/L				0			05/13/2021 08:56:48	C.S.	
Antimony	<0.5	ug/L		6		0.5			05/13/2021 08:56:48	C.S.	
Arsenic	<0.5	ug/L		10		0.5			05/13/2021 08:56:48	C.S.	
Barium	0.0072	mg/L		2		0.0005			05/13/2021 08:56:48	C.S.	
Beryllium	<0.5	ug/L		4		0.5			05/13/2021 08:56:48	C.S.	
Cadmium	<0.5	ug/L		5		0.5			05/13/2021 08:56:48	C.S.	
Calcium	11	mg/L				0.05			05/13/2021 08:56:48	C.S.	
Chromium	<0.0005	mg/L		.1		0.0005			05/13/2021 08:56:48	C.S.	
Copper	0.023	mg/L		1.3		0.001			05/13/2021 08:56:48	C.S.	
Iron	0.23	mg/L		.3		0.05			05/13/2021 08:56:48	C.S.	
Lead	4.3	ug/L		15		0.5			05/13/2021 08:56:48	C.S.	
Magnesium	1.6	mg/L				0.05			05/13/2021 08:56:48	C.S.	
Manganese	0.028	mg/L		.05		0.0005			05/13/2021 08:56:48	C.S.	
Mercury	<0.1	ug/L		2		0.1			05/13/2021 08:56:48	C.S.	
Nickel	<0.0005	mg/L		0.02		0.0005			05/13/2021 08:56:48	C.S.	
Selenium	<0.0005	mg/L		0.05		0.0005			05/13/2021 08:56:48	C.S.	
Silver	<0.0005	mg/L		.1		0.0005			05/13/2021 08:56:48	C.S.	
Sodium	14	mg/L				0.05			05/13/2021 08:56:48	C.S.	
Thallium	<0.0005	mg/L		.002		0.0005			05/13/2021 08:56:48	C.S.	
Uranium	<0.5	ug/L		30		0.5			05/13/2021 08:56:48	C.S.	
Zinc	0.0067	mg/L		5		0.001			05/13/2021 08:56:48	C.S.	
pH (4500-H+B)	6.7	S.U.		8.5			8.5	6.5	05/14/2021 15:08:00	A.B.	
Turbidity (180.1)	<0.6	NTU				0.6			05/12/2021 16:34:00	L.D.	