Continued from Previous Page

Lab Sample#: *2402815-01* Sample Address:

Sample Matrix: DW-H20 Sample Point: TP-1 Surface:

Description: AFTER TREATMENT & BEFORE DISTRIBUTION EP (INTERVALE WE Sample Date: 04/25/2024 Sample Time: 09:47:00

Test (Method)/Analyte	Result	Unit	Qualifiers	MCL	RL	High Limit	Low Limit	Analysis Date	Analyst
ANIONS_DW (300.0)									
Sulfate	7	mg/L		250	1			04/25/2024 15:19:00	M.E.
Fluoride	<0.05	mg/L		4	0.05			04/25/2024 15:19:00	M.E.
Chloride	27	mg/L		250	1			04/25/2024 15:19:00	M.E.
Nitrite Nitrogen	<0.05	mg/L		1	0.05			04/25/2024 15:19:00	M.E.
Nitrate Nitrogen	0.23	mg/L		10	0.05			04/25/2024 15:19:00	M.E.
Color (L-10-308-00-1-A)	<5	PCU	J	15	5			04/25/2024 16:05:56	K.M.
METALS_200.8 (200.8)									
Total Hardness	34	mg/L			0			05/01/2024 14:33:12	I.M.
Antimony	<0.5	ug/L		6	0.5			05/01/2024 14:33:12	I.M.
Arsenic	<0.5	ug/L		10	0.5			05/01/2024 14:33:12	I.M.
Barium	0.0080	mg/L			0.0005			05/01/2024 14:33:12	I.M.
Beryllium	<0.5	ug/L			0.5			05/01/2024 14:33:12	I.M.
Cadmium	<0.5	ug/L		5	0.5			05/01/2024 14:33:12	I.M.
Calcium	11	mg/L			0.05			05/01/2024 14:33:12	I.M.
Chromium	<0.0005	mg/L		.1	0.0005			05/01/2024 14:33:12	I.M.
Copper	<0.001	mg/L		1.3	0.001			05/01/2024 14:33:12	I.M.
Iron	0.22	mg/L			0.05			05/01/2024 14:33:12	I.M.
Lead	4.6	ug/L		15	0.5			05/01/2024 14:33:12	I.M.
Magnesium	1.6	mg/L			0.05			05/01/2024 14:33:12	I.M.
Manganese	0.029	mg/L			0.0005			05/01/2024 14:33:12	I.M.
Mercury	<0.1	ug/L		2	0.1			05/01/2024 14:33:12	I.M.
Nickel	<0.0005	mg/L			0.0005			05/01/2024 14:33:12	I.M.
Selenium	<0.0005	mg/L			0.0005			05/01/2024 14:33:12	I.M.
Silver	<0.0005	mg/L			0.0005			05/01/2024 14:33:12	I.M.
Sodium	17	mg/L			0.05			05/01/2024 14:33:12	I.M.
Thallium	<0.0005	mg/L			0.0005			05/01/2024 14:33:12	I.M.
Uranium	<0.5	ug/L		30	0.5			05/01/2024 14:33:12	I.M.
Zinc	<0.001	mg/L			0.001			05/01/2024 14:33:12	I.M.
pH (4500-H+B)	7.5	S.U.		8.5		8.5	6.5	04/26/2024 10:25:00	L.S.
Turbidity (180.1)	<0.6	NTU			0.6			04/25/2024 16:12:00	A.M.

Color is analyzed by the Lachat Method 10-308-00-1-A. Color was not analyzed by an approved accredited method.

Attached By K.M. Date 04/25/2024 Time 16:33:22